



Department of Community Development and Sustainability

23 Russell Boulevard, Suite 2 Davis, California 95616

Phone: (530)757-5610 TDD: (530)757-5666

Website: <http://community-development.cityofdavis.org/>

Email: cddweb@cityofdavis.org

SMOKE AND CARBON MONOXIDE ALARMS SELF-CERTIFICATION FORM

Building Permit # _____ **Address** _____

The California Residential Code (CRC) requires that when a permit is required for alterations and additions to a dwelling, the Building Division shall verify that smoke and carbon monoxide (CO) alarms are installed and functional.

Smoke alarms shall be installed in accordance with the approved manufacturer's instructions in all of the following areas:

- a. Each sleeping room.
- b. Outside each separate sleeping area in the immediate vicinity of the bedrooms
- c. One on each floor, if a multi-story
- d. In the basement, if a basement exists (must be installed on ceiling near the entry to the stairs)

Note: Smoke alarms shall not be installed within 3' of bathroom door, fan or supply registers.

Carbon Monoxide alarms shall be installed in accordance with the approved manufacturer's instructions in all of the following areas where fossil fuel burning appliances are installed or have attached garages.

- a. Outside each sleeping unit
- b. On every floor level of dwelling unit, including basements.

I declare under penalty of perjury that the residence listed is in full compliance with the above smoke and carbon monoxide alarms requirement mandated by the California Residential Code and State law.

Property Owner's or Contractor's Name (print) _____

Signature _____

If you have questions concerning this requirement please contact the Building Division by email Buildinginfo@cityofdavis.org or by telephone at (530) 757-5610.